

FIRE PITS REGULATIONS

Permits are not required for fire pits but the following regulations must be followed:

1. A minimum of 3 m clearance, measured from the nearest fire pit edge is maintained from buildings, property lines, or other combustible material;
2. The fire pit height does not exceed 0.6 m when measured from the surrounding grade to the top of the pit opening;
3. The fire pit opening does not exceed 1 m in width or in diameter when measured between the widest points or outside edges;
4. The fire pit installation has enclosed sides made from bricks, concrete blocks, heavy gauge metal, or other non-combustible materials acceptable to the Manager, Fire Services; and
5. A spark arrestor mesh screen with openings no larger than 1.25 cm and constructed or expanded metal (or equivalent non-combustible material) is used to cover the fire pit opening in a manner sufficient to contain and reduce the hazards of airborne sparks.

FOR MORE INFORMATION ON FIRE PITS YOU CAN CALL THE FIRE
DEPARTMENT AT 780-980-8475.