



OUTDOOR BURNING CHECKLIST

Name of Company _____ Date of burn from/to _____

Name of Person Responsible _____ PH# _____

Street Address _____ Subdivision _____

Location of Burn Bin on Property _____

	Item	Code Reference	Yes/No or N/A
1)	Is address visible from street/highway	Bylaw 495-2001	
2)	Weather conditions Winds <25Km/hr.	Bylaw No. 351-95	
3)	Is an appropriate burn container being used	AFC 3.3.2.8. 1)	
4)	Wind direction cause smoke to enter buildings or work areas	AFC 3.3.2.8. 3)	
5)	Fire department has access to burn, min 6 meters in width	AFC 3.3.2.5. 1)	
6)	Is burn located away from buildings Min distance 15 meters	AFC 3.3.2.8.3 b) AFC 2.4.5.1. 1)	
7)	Area around burn is clear of debris, garbage and long grass/weeds	AFC 3.3.2.8. 1)	
8)	Is burn located on a noncombustible surface Describe _____ _____	AFC 3.3.2.11	
9)	Are ordinary combustibles being burned only Describe _____ _____	Bylaw No. 351-95	
10)	Is there a fire watch in place Describe _____ _____ _____	AFC 2.8 Bylaw No. 351-95 6.2	
11)	Is there firefighting equipment in the vicinity Describe _____ _____	AFC 3.3.2.10 Bylaw No. 351-95 6.2	
12)	Is there a permit issued for burn Permit# _____	Bylaw No. 351-95 6.1	